



### State of Oregon - Drinking Water Program

#### Microbiological Analysis (Coliform) Reporting Form for Public Water Systems

**PWS ID #:** 41- 00851  
**System Name:** Sweet Home, City of  
**City, County:** Sweet Home, Linn  
**Phone #:** 541-401-3336  
**Fax #:** 541-367-6440  
**Name:** Dominic Valloni  
**Address:** 1400 24th Ave  
**City, State, Zip:** Sweet Home, OR 97386  
**Sample Source:** Distribution  
**Sample Type:** Routine  
**Chlorinated:**  No  Yes

**Analytical Laboratory Group, Inc.**  
 361 West Fifth Avenue • Eugene, Oregon 97401  
 1-800-262-5973 • 541-485-8404  
 Fax: 541-484-5995  
 Accredited in accordance with NELAP  
 ORELAP Lab ID OR100012

---

**Method: Colilert, SM 9223B 2004**  
 **Method: Colilert 18<sup>®</sup>**

**Results Codes: P=Present A=Absent**

**Shipped Via:** Western Express  
**Samples Received Date/Time:** 11/21/23 09:10 **Initials:** MT **Temp:** 8.4 °C **Evidence of cooling?** Ice

Water Sampler Use						Laboratory Use									
Collection		Site Location		Cl <sub>2</sub>		Sample ID#	Analysis Start			Test Results		Analysis Complete			
Date	Time	Site ID	Site Address	mg/L	Initials	<u>2311645</u>	Date	Time	Initials	TC	E. Coli	Date	Time	Initials	
11/21/23	7:10am	6	912 Pinetop St.	0.80	WG	001	11/21/23	1343	SS	A	A	11/22/23	1558	SS	
11/21/23	7:50am	7	49th St. Reservoir	0.78	WG	002				A	A				
11/21/23	7:40am	8	1286 40th Ave	0.64	WG	003				A	A				
11/21/23	7:20am	9	910 29th Ave	0.87	WG	004				A	A				
11/21/23	7:20am	10	1057 15th Ave	0.92	WG	005	11/21/23	1343	SS	A	A	11/22/23	1558	SS	

All results meet NELAP requirements unless otherwise stated. Positive results to be faxed to DHS-DWP within 24 hours to (971) 673-0458.

**Reviewed by:** Kimberly J Ren Morgan  
**Reported by:** Kimberly J Ren Morgan

**Review Date:** 11/22/2023  
**Report Date:** 11/22/2023

**Notes:**